

Government of Bihar
Public Health Engineering Department
Water Quality Test Report

District Name: Gopalganj

Division Name: P.H.Division Gopalganj


Sample Code GPJ 02

SL. No.	Block	Panchayat	Village	Ward No.	Location of Source	Parameters														Date of Testing	Remarks
						pH	Turbidity (NTU)	EC	TDS (mg/l)	Total Hardness (mg/l)	Calcium (mg/l)	Magnesium (mg/l)	Chloride (mg/l)	Total Alkalinity (mg/l)	Iron (mg/l)	Nitrate (mg/l)	Sulphate (mg/l)	Fluoride (mg/l)	Total Coli		
1	Gopalganj	Basdilakhas	Basdilakhas	8	C.B.Sec.Edu.Public School	7.43	0.1	572	372	260	64	28	20	280	0.29	0.54	122	0.49	Absent	30/04/2026	
Desirable Limit*						6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	-		
Permissible Limit* in absence of alternate source (IS 10500:2012 - 2nd revision & Rev 2015)						NR	5.0	-	2000	600	200	100	1000	600	1.0	NR	400	1.5	**		



30.04.26

Chemist / Lab Asst

DLL, P.H. Division, Gopalganj


30/4/2026
AE

P.H.Division, Gopalganj


30/4/26

Executive Engineer
P.H.Division, Gopalganj